

- REA-Abwasseranlage 1 -															Blatt 6
Mon	Zusatz- menge	Abwass. menge	Temp.	Absatz Stoffe	Abfilt Stoffe	CSB	Cd	Hg	Cr gesamt	Ni	Zn	Pb	Cu	As	Tl
	m3	m3	°C	ml/l	mg/l										
1	72786	14364	35.0	---	6	38	0.002	0.001	0.010	0.014	0.045	0.005	0.011	0.002	0.015
2	70131	11464	33.8	---	7	40	0.002	0.001	0.008	0.010	0.052	0.005	0.006	0.001	0.012
3	74293	15039	36.5	---	8	38	0.002	0.002	0.009	0.010	0.060	0.005	0.007	0.002	0.012
4	53031	13651	36.8	---	9	36	0.003	0.002	0.009	0.010	0.059	0.005	0.004	0.002	0.019
5	29887	11584	38.0	---	7	30	0.003	0.002	0.005	0.010	0.057	0.010	0.013	0.004	0.019
6	38110	11763	40.3	---	11	28	0.002	0.004	0.015	0.010	0.061	0.010	0.010	0.006	0.017
7	56990	16319	38.6	---	8	33	0.006	0.002	0.016	0.010	0.072	0.007	0.009	0.004	0.017
8	50420	10583	36.9	---	9	40	0.010	0.001	0.009	0.010	0.078	0.005	0.010	0.002	0.015
9	83678	17992	38.5	---	8	39	0.010	0.001	0.018	0.010	0.054	0.005	0.011	0.002	0.002
10	87240	18004	38.4	---	5	43	0.006	0.001	0.012	0.010	0.020	0.005	0.012	0.001	0.024
11	76392	17023	36.6	---	6	44	0.009	0.001	0.006	0.010	0.020	0.005	0.010	0.001	0.024
12	77317	17788	35.3	---	8	34	0.005	0.002	0.019	0.079	0.020	0.005	0.015	0.002	0.038
Min	29887	10583	33.8	---	5	28	0.002	0.001	0.005	0.010	0.020	0.005	0.004	0.001	0.002
M/S	77027	175574	37.0	0.0	8	37	0.005	0.002	0.011	0.016	0.050	0.006	0.010	0.002	0.018
Max	87240	18004	40.3	---	11	44	0.010	0.004	0.019	0.079	0.078	0.010	0.015	0.006	0.038

**Grenzwerte:      30      80      0,03   0,03      0,3      0,3      0,6      0,06      0,3      0,15      0,05**

- REA-Abwasseranlage 2 -									Blatt 7	
Mon	F	Cl	SO4	NH4-N	NO2-N	NO3-N ges.	N ges.	Dioxine Furane		
	mg/l	g/l	mg/l		mg/l			ng/l		
1	9.5	1.38	1625	0.77	0.32	102.7	103.7	---		
2	8.7	1.57	1643	1.08	0.43	115.9	117.4	---		
3	8.8	2.00	1498	0.89	0.39	115.2	116.5	0.010		
4	7.6	2.29	1286	2.10	0.32	95.40	97.82	---		
5	8.3	1.49	1438	4.90	0.54	78.18	83.61	---		
6	9.5	1.29	1548	1.41	0.44	81.98	83.82	0.159		
7	8.4	1.22	1360	0.78	0.13	75.84	76.75	---		
8	8.5	1.18	1455	2.28	0.47	84.10	86.85	---		
9	9.6	1.24	1512	1.24	0.22	104.3	105.8	0.004		
10	8.3	1.32	1540	3.72	0.29	101.6	105.6	---		
11	8.1	1.23	1523	5.67	0.44	85.25	91.37	---		
12	7.6	1.10	1529	2.47	0.55	82.43	85.45	0.007		
Min	7.6	1.10	1286	0.77	0.13	75.84	76.75	0.004		
M/S	8.6	1.44	1496	2.28	0.38	93.59	96.24	0.045		
Max	9.6	2.29	1643	5.67	0.55	115.9	117.4	0.159		

Grenzwerte: 30

2,000

25

190

0,3